



SCADAPack 32 Controllers

Schneider Electric, Telemetry & Remote SCADA Solutions (Control Microsystems) confirms that the SCADAPack firmware providing DNP3 protocol operation on the following devices has been tested and conforms to the requirements of the DNP Users Group conformance testing policy.

SCADAPack 32 Controllers:

- SCADAPack 32 (all models)
- SCADAPack 32P (all models)



Manufacturer:	Control Microsystems Inc.
Device Model:	SCADAPack 32
Firmware Version:	1.21
Subset Tested:	Level 2
Test Version:	DNP3 2002 IED Certification Procedure Subset Level 2
Date Tested:	2 nd June, 2003
Test Status:	Passed
Test Facility:	Self Tested Control Microsystems (Kanata, Ontario, Canada)
Tester:	Rudolph Griffith

Wade Neville
Director of Engineering
Schneider Electric, Telemetry & Remote SCADA Solutions