



## SCADAPack E Controllers

Schneider Electric, Telemetry & Remote SCADA Solutions (Control Microsystems) confirms that the SCADAPack firmware providing DNP3 protocol operation on the following devices has been tested and conforms to the requirements of the DNP Users Group conformance testing policy.

SCADAPack E Controllers:

- SCADAPack 314E, 330E, 334E, 350E, 357E (all models)
- SCADAPack ES / Serck Controls 586 eNET (all models)
- SCADAPack ER / Serck Controls Magna/eNET (all models)



|                          |  |
|--------------------------|--|
| <b>Manufacturer:</b>     | Control Microsystems Inc.  |
| <b>Device Model:</b>     | SCADAPack E Controllers  |
| <b>Firmware Version:</b> | 8.00   |
| <b>Subset Tested:</b>    | Level 2  |
| <b>Test Version:</b>     | Version 2.6 IED Certification Procedure<br>Subset Level 2 Rev 1(DNP3-2009) |
| <b>Date Tested:</b>      | 3 <sup>rd</sup> December, 2010   |
| <b>Test Status:</b>      | Passed   |
| <b>Test Facility:</b>    | Self Tested<br>Control Microsystems (Kanata, Ontario, Canada)              |
| <b>Tester:</b>           | Rudolph Griffith   |

Wade Neville  
Director of Engineering  
Schneider Electric, Telemetry & Remote SCADA Solutions